

Annual AT&C Loss (FY2019-2020)

Name of District	Energy Input (MU)	Energy Billed (MU)	D&B Losses (%)	Amount Billed (Rs. Cr.)	Amount Realized (Rs. Cr.)	Coll. Eff. (%)	Average Rate of billing (Rs./Kwh)	Energy Realized (MU)	AT&C Losses (%)
Badli	666.40	627.01	5.91%	592.67	585.42	98.78%	9.45	619.35	7.06%
Bawana	1426.01	1281.74	10.12%	1382.19	1357.77	98.23%	10.78	1259.10	11.70%
Civil Lines	761.25	727.19	4.47%	648.97	639.84	98.59%	8.93	716.97	5.82%
Keshav Puram	658.03	627.99	4.57%	612.63	603.03	98.43%	9.76	618.15	6.06%
Mangolpuri	805.46	740.78	8.03%	543.75	543.42	99.94%	7.34	740.33	8.09%
Model Town	541.26	514.79	4.89%	446.53	442.01	98.99%	8.68	509.58	5.85%
Moti Nagar	817.52	784.16	4.08%	778.56	773.25	99.32%	9.93	778.81	4.73%
Narela	1192.19	1079.66	9.44%	1099.73	1079.61	98.17%	10.19	1059.90	11.10%
Pitam Pura	662.14	624.84	5.63%	560.17	557.00	99.43%	8.97	621.30	6.17%
Rohini	909.71	856.85	5.81%	712.45	708.01	99.38%	8.32	851.52	6.40%
Shakti Nagar	362.67	342.33	5.61%	304.49	300.28	98.62%	8.89	337.60	6.91%
Shalimar Bagh	949.07	878.38	7.45%	654.56	653.75	99.88%	7.46	877.29	7.56%
TPDDL Total	9751.72	9085.73	6.83%	8336.70	8243.39	98.88%	9.18	8984.04	7.87%

Note:-

All the above figures have been truncated to two decimal places. Energy Realized (MU) data (at TPDDL level) has been calculated as per average billing rate(at TPPDL level).